



ODISHA POWER TRANSMISSION CORPORATION LIMITED
(A Government of Odisha Undertaking)
OFFICE OF THE DEPUTY GENERAL MANAGER (ELECT.),
EHT(O&M) DIVISION, CHOUDWAR
AT/PO-KAPALESWAR, DIST-CUTTACK, PIN-754071
TELEPHONE NO-0671-2394247
Email id: ehtm.div.cdw @optcl.co.in
CIN-U401020OR2004SGC007553

LT . NO. EHT/CDR/ - 100

DATE: 20/01/2018

1st CORRIGENDUM TO TENDER CALL NO 03 / 2017-18

Due to typographical error, the following amendments are as follows :-

1. **Serial No. 4 of Section-III:-** Width of cable tray may be read as 300mm instead of 450mm.
2. **Serial No. 6 of Section-III may be read as follows: -**
 - a) The cable tray including tees should confirm to **IS 737:1986** for wrought Aluminium and Aluminium alloy sheet & strip for general engineering purposes.
 - b) The nuts & bolts along with the washers should be of stainless steel as per relevant IS Specification.

All other terms and conditions of tender call notice will remain unaltered.


Dy. General Manager(Elect.)
EHT (O & M) Division, Choudwar

CC To the :-

- (i) Chief General Manager (O&M), OPTCL, Bhubaneswar for favour of kind information.
- (ii) Chief General Manager (IT), OPTCL Bhubaneswar for favour of kind information.
He is requested to upload the same in OPTCL website for information of all concerned.
- iii) Chief General Manager (F), OPTCL, Bhubaneswar for favour of kind information.
- (iv) General Manager, EHT(O&M) Circle, Cuttack for favour of kind information.
- (v) D.G.M. EHT(O&M) Division, Bhubaneswar/Cuttack/ Paradeep / E&MR Division, Bhubaneswar for information and wide circulation. They are requested to exhibit the corrigendum notice in their office notice board for wide publicity.
- (vi) Notice Board / Junior Manager (F) of this office.
- (vii) Copy to all SDO, under this Division for information.
- (viii) Tender processing file for reference and record.