



ଓଡ଼ିଶା ବିଦ୍ୟୁତ ଶକ୍ତି ସଂଚାରଣ ନିଗମ ଲିଡ.
ODISHA POWER TRANSMISSION CORPORATION LTD.
O/O : G.M. (ELECT.) E.H.T. (O&M) CIRCLE, BURLA,
DIST: SAMBALPUR (ODISHA) 768017

Corrigendum to TENDER NOTICE NO. BRL-13/19-20

NO-EHTM/BRL/TENDER/

1022

DATE: 18.10.2019

CORRIGENDUM-2

With reference to the tender call notice No. BRL-13/19-20, the SI No.1 & 4 of Part-A of specification to be read as follows.

1. Specification of pole: Height of pole 7Mtrs. Bottom dia 160mm, Top Dia 104mm, thickness of sheet: 3mm, Base plate dimension: (LxBxT) 275mmx275mmx16mm, Foundation of Pole Steel grade EN-8, Bolt Size- (NoxDia) 4x24mm, Pitch Circle Dia: 270mm Bolt length: 750mm, Projected bolt length: 125mm, Single arm designer bracket length: 1Mtr. long.
4. Supply & trenching & laying of 25sq.mmx3.5Core armour cable, cable must be run in one Ft Depth inside of duct, soil & bricks cushion, refilling of soil as before. – 570Mtr.

All other terms & conditions will remain constant.

N.B:- All subsequent addendums/corrigendum to the tender shall be hosted in the OPTCL's official web site <http://www.optcl.co.in>.


General Manager (Elect.)
E.H.T. (O&M) Circle, Burla