



ଓଡ଼ିଶା ବିଦ୍ୟୁତ ଶକ୍ତି ସଂଚାରଣ ନିଗମ ଲିଡ଼.
ODISHA POWER TRANSMISSION CORPORATION LIMITED

(A Government of Odisha Undertaking)

CIN – U40102OR2004SGC007553

OFFICE OF THE GENERAL MANAGER, (Elect)

EHT (O&M) Circle, Cuttack.

At: Madhusudan Nagar, P.O: Tulsipur, Cuttack-753008.

Tel-(0671)-2970227, E-mail: ehtm.cle.ctc@optcl.co.in

No. EHTM/GM/ETCN/08/CTC/23-24/

384

/Dated, 24.07.2023

E-Tender Call Notice Nos. 08/CTC/2023-24

ADDENDUM NO -1

- The Technical Specification at Section III, Part I of the tender specification for E-Tender Call Notice number 08/CTC/2023-24 regarding “Supply of 220kV, 132kV & 33kV switchyard Bay Marshalling Kiosks for SAS Project Work (Under PSDF) of 220/132/33kV Grid Substation, Paradeep”, has been revised at parts as per the serial number detailed below and are highlighted / written in red font.
- **As the technical specification has been modified, the price bid has been revised and re-uploaded accordingly.** The tenderers who have already submitted their price, are requested to re-submit their price bids.
- **All other terms & conditions remain unaltered.**

N.B: All subsequent addendums/corrigendum to the tender shall be hosted in the OPTCL's official web site <http://www.optel.co.in> and www.tenderwizard.com/OPTCL only.

ms
24.07.2023
General Manager (Elec)
EHT (O&M) Circle, Cuttack

PART-I
(SECTION-IV)

**TECHNICAL SPECIFICATION FOR 220kV, 132kV & 33kV SWITCHYARD BAY
MARSHALLING KIOSKS FOR SAS PROJECT WORK (UNDER PSDF) OF
220/132/33kV GRID SUBSTATION, PARADEEP**

220kV S/Y BMK

Sl. No	Type of Feeder	No. of Feeders	Voltage & Phase	Current rating	Controlled by	Pole & Neutral
5.	Outgoing	8	240V, 1Ø	16A, 10kA	MCB	DP

132kV S/Y BMK

Sl. No	Type of Feeder	No. of Feeders	Voltage & Phase	Current rating	Controlled by	Pole & Neutral
4.	Outgoing	20	415V, 3Ø	32A, 10kA	MCB	TPN (4P)
5.	Outgoing	8	240V, 1Ø	16A, 10kA	MCB	DP

33kV S/Y BMK

Sl. No	Type of Feeder	No. of Feeders	Voltage & Phase	Current rating	Controlled by	Pole & Neutral
3.	Outgoing	20	415V, 3Ø	32A, 10kA	MCB	TPN (4P)
4.	Outgoing	10	240V, 1Ø	16A, 10kA	MCB	DP

Bill of Quantity

SL. NO.	DESCRIPTION	TOTAL QTY.			MAKE
		220kV BMK	132kV BMK	33kV BMK	
21	POWER - TERMINAL - BLOCK CONNECTOR - 32A (CATM4)	80	90	90	ELMEX/CON.WELL
22	POWER - TERMINAL - BLOCK CONNECTOR-16A (CATM3)	20	20	25	ELMEX/CON.WELL

ms
24.07.2023
General Manager (Elec)
EHT (O&M) Circle, Cuttack