

CENSUS OF EHV TRANSFORMERS IN OPTCL SYSTEM(AS ON 10th Aug'2026)

Voltage Ratio (kV)	Rating (MVA)	No. of Transformers installed	Total Installed Capacity (MVA)
400/220 kV (ICT)	500	4	2,000
	315	8	2,520
	Sub-Total	12	4,520
220/132 kV (AUTO)	160	64	10,240
	100	19	1,900
	50	0	0
	Sub-Total	83	12,140
220/33 KV	63	4	252
	40	21	840
	20	27	540
	Sub-Total	52	1,632
132/33 kV	63	29	1,827
	40	150	6,000
	35	2	70
	31.5	5	158
	20	149	2,980
	16	0	0
	12.5	49	612.5
	10	1	10
	7.5	0	0
	5	0	0
	Sub-Total	385	11,657.0
TOTAL		532	29,949