


SECTION-1



ଓଡ଼ିଶା ବିଦ୍ୟୁତ ଶକ୍ତି ସଂଚାରଣ ନିଗମ ଲିଡ. ODISHA POWER TRANSMISSION CORPORATION LTD.

(A Government of Odisha under taking)

Regd. Office: Janpath, Bhubaneswar-751022, Odisha

OFFICE OF THE GENERAL MANAGER (ELECT.)

EHT (O&M) CIRCLE: BURLA,

AT/PO – BURLA, DIST.: SAMBALPUR – 768017

TELE/FAX: (0663) 2430160, e-mail: ehm.cle.brl@optcl.co.in

CIN: U40102OR2004SGC007553

TENDER CALL NOTICE NO. BRL-10/2025-26

Sealed tenders are invited by the undersigned from reputed manufactures/ distributors/ Dealer, PAN., GSTIN for “Supply of 120 Nos. of surge counters for LAs of different feeder bays of different Grid Sub-Station under EHT (O&M) Division, Jharsuguda”.

Sl. No.	Tender Call Notice No.	Description of Materials	Cost of Tender Paper	EMD
1	BRL-10/2025-26	Surge Monitor along with Leakage current Meter/Counter Type: Non-Reset type, Lightening Arrestor: MAKE: OBLUM/ LAMCO/ Any reputed make. Range of Milli Ammeter – Complete Range: 0-10 mA, Green (Healthy) range: 6-10 mA & Red (Danger) range: 6-10 mA Nominal Discharge Current- 10 KA	Rs. 4000/- + GST @ 18%= Rs. 4,720/-	1% of Quoted amount

SALE OF TENDER SPECIFICATION	:	DT. 02.08.2025 (From- 10:00 AM)
LAST DATE SALE OF TENDER SPECIFICATION	:	DT. 18.08.2025 (To- 05:00 PM)
LAST DATE OF SUBMISSION OF TENDER	:	DT. 19.08.2025 (By- 01:30 PM)
DATE OF OPPENING OF PRICE BID	:	DT. 19.08.2025 (On- 4:30 PM)

The tender documents can be made available and received in the office of the undersigned on written request towards cost of tender documents by cash/pay order/D.D. in favour of “E.H.T. (O&M) Circle, OPTCL, Burla” payable at Burla. Additional amount of Rs. 100/- (Rupees one hundred) only may be paid for the postal delivery of the tender documents. The undersigned shall not be responsible for any postal delay at any stage.

The tender must be accompanied with requisite EMD amount equal to 1% of the quoted value for each groups in shape of Cash/ DD/Pay order in favour of **"E.H.T. (O&M) Circle, OPTCL, Burla" payable at Burla**" The tender documents will be opened in the office of the undersigned in the presence of the tenderer or their authorized representatives if any. Incomplete tender, tender without EMD and the tender received after the due date and time shall be liable for rejection. If the date of tender opening falls on holiday, the same will be opened on the next working day.

The tender document must be accompanied by the following documents failing which the offer will be out-rightly rejected.

- (1) Requisite EMD in shape of cash deposited in this office/D.D/Pay order.
- (2) Original cash receipt towards procurement of tender specification.
- (3) Copy of Valid manufactures/ distributors/ dealer.
- (4) Copy of PAN card.
- (5) Copy of GSTIN.

The undersigned reserves the right to vary any quantity/accept or reject any or all the tenders without assigning any reason thereof.



**General Manager (Elect.)
E.H.T. (O&M) Circle, Burla.**

SECTION-IV

TECHNICAL SPECIFICATION FOR SURGE MONITORS WITH COUNTERS

The equipment covered by this specification shall unless otherwise specified, be built to conform to Indian Electricity Rules 1956 wherever applicable. Permissible temperature rise shall be as per relevant ISS.

Lightening Arrestor: MAKE: OBLUM/ LAMCO/ Any reputed make.

Type: Non-Reset type,

Range of Milli Ammeter –

Complete Range: 0-10 mA,

Green (Healthy) range: 6-10 mA &

Red (Danger) range: 6-10 mA

Nominal Discharge Current- 10 KA

Surge Monitor: Hermitically sealed unit consisting of cyclometric surge counter and leakage current monitor.

Surge Counter: Electromechanically operating 6 digit cyclometric counter indicates the number of surges handled by the arrester.

Leakage Current Monitor: Miliameter indicates the total power frequency leakage current flowing through the Arrester.



**General Manager (Elect.)
EHT (O&M) Circle, Burla**