

ଓଡ଼ିଶା ବିଦ୍ୟୁତ୍ ଶକ୍ତି ସଂଚାରଣ ନିଗମ ଲିଃ

ODISHA POWER TRANSMISSION CORPORATION LTD

(A Government of Odisha Undertaking)

Office of the Deputy General Manager (Elect.)

EHT (O&M) Division LAPANGA, AT/PO: - LAPANGA, DIST: - SAMBALPUR-768212

Date: 22.01.2025

Email: ehtm.div.lpnga@optcl.co.in

CORRIGENDUM TO E-TENDER CALL NOTICE NO. LPNGA/ 04/24-25

Letter No. EHTM/LPNGA/TECH/67/2025

CORRIGENDUM

With reference to the E-Tender call notice No._LPNGA/ 04/24-25,the last date of sale,receipt and opening of tender paper is hereby extended as given below. Also the tender specification has been updated as follows.

Date of sale of Tender Paper	:	Up to 30.01.2025
Last Date & time of receipt of Tender documents	:	31.01.2025 up to 01:00 PM at EHT(O&M) Division,Lapanga
Date of opening of Tender Paper	:	On 31.01.2025 at 03:00PM

TECHNICAL SPECIFICATION

1) Resolution: 384x288 Pixel (With super resolution facility)

2) Visible camera resolution: 8MP3) Frame rate: 30Hz

4) Measuring Range: 20°C-650°C, with temperature alarm facility
5) Screen: 4.3 inch graphical display with Touch screen

6) Memory: Standard 32GB SD card

7) Battery: Li-ion rechargeable battery with charger ,battery backup more than 6 Hrs

8) GPS & Compass facility required.

9) Visibility: More than 30 Meter.

10) Focus: Screen touch focus, Auto focus, Laser focus.

Central spot measurement/Hotspot and cold spot tracing, Image modes, Thermal imaging, Thermal fusion, PIP, Visible imaging, FOV 27º x 20º, IFOV1.31mrad,1 to 16 x digital zoom, Timed photographing on the device for continuous monitoring, Wifi Connectivity, Additional battery included as standard etc...

*The firm must present a comprehensive demonstration of the thermovision camera, highlighting its capabilities and features in a clear and engaging manner.

All other terms & conditions will remain unaltered.

N.B:- All subsequent addedums/corrigendum to the tender shall be hosted in the OPTCL's official website.

Dy. General Manager (El.) EHT (O&M) Division, Lapanga